

## Thermal Physics, Acoustics and Environment Department

Ksawerów 21, 02-656 Warsaw,  
tel.: 22 5664 133; fizyka@itb.pl  
Thermal Physics Section  
tel.: 22 5664 269,183; fizyka@itb.pl  
Department at Katowice;  
al. W. Korfanteo 191, 40-153 Katowice  
tel.: 32 7302 925; fizyka@itb.pl  
Acoustics Section  
tel.: 22 5664 311; akustyka@itb.pl  
Energy and Environmental Efficiency Workshop  
tel.: 22 5664 352; energia@itb.pl  
Environmental Chemistry Laboratory  
tel.: 22 5796 187; chemia@itb.pl

Warsaw, 16.12.2025

## PORTOS TR7 Spółka z ograniczoną odpowiedzialnością

ul. Żłota 71  
62-800 KALISZ

In correspondence, please provide the following code:

**NZF.410.832.2025 05710.22.JA**


**IT CONCERNS:** LZF00-02635/25/Z00NZF

**OBJECT TESTED:** Aluminum profile of the roller shutter curtain PA-39.

**TEST RESULT:** The thermal transmittance  $U$  of the aluminum profile of the PA-39 roller shutter curtain, shown in the drawing, calculated according to PN-EN ISO 6946:2017-10 is equal to:

$$U = 6.0 \text{ W}/(\text{m}^2 \cdot \text{K})$$

**DOCUMENT NUMBER:** LZF00-02635/25/Z00NZF



**M.Sc. Eng. Jarosław Awksientjuk**  
Person responsible for tests  
/qualified digital signature/

**PhD Eng. Agnieszka Winkler-Skalna**  
Head of the Department of Thermal Physics,  
Acoustics and Environment  
/qualified digital signature/

A document with a qualified electronic signature whose certificate has already expired is still valid (the certificate was valid on the day the document was signed).